

SYMBOL CABLE DETAIL

- 1

NY1x3-240 sqmm,
NY11x25sqmm,G
IN 28100mm,LMC

RTD CABLE
BY Manufacturer
INØ32mm,LMC

FOR PUMP
- 2

12/C-1.5sqmm,
CVV
INØ25mm,LMC,
4C-4sqmm,
INØ32mm,LMC.

VCT-GRO
FOR VALVE
- 3

3C-4/4G mm NY1-G
IN Ø40mm, HDPE

FOR TRASH RACK
- 4

19C-2.5 mm CVV-F
IN Ø32mm, HDPE

FOR LOCAL PANEL
- 5

19C-2.5 mm CVV-F
IN Ø32mm, HDPE

FOR FLOAT SWITCH
- 6

SIGNAL Cable
BY Manufacturer
3C-4 mm NY1-G
IN 2832mm, HDPE

FOR ULTRASONIC LEVEL
- 7

4x1C-16 mm IEC0502-1
1C-6 mm LEGOT GROUND
IN Ø40mm, HDPE

FOR CRANE


FIELD BOOK NO.	
PROFILE	ALIGNMENT

SURVEY		/	/
DRAWN		/	/
CHECKED		/	/



แสดงแนวเดินสายไฟฟ้าสถานสูบน้ำภาคคลองบางตลาด

มาตราส่วน 1:200



REV.	DESCRIPTION	ENGINEER	DOH
NO.		CHECKED DATE	CHECKED DATE

KINGDOM OF THAILAND	
MINISTRY OF TRANSPORT	
DEPARTMENT OF HIGHWAYS	

โครงการศึกษาการแก้ไขปัญหาน้ำท่วม	
บนทางหลวงหมายเลข 304 (แจ้งวัฒนะ)	
ฝั่งตะวันตกสายไฟฟ้าสถานีสูบน้ำภาคคลองบางตลาด	

บริษัท ทีม คอนซัลติ้ง เอนจิเนียริ่ง	
แอนด์ แมเนจเม้นท์ จำกัด (มหาชน)	
บริษัท ดาวฤกษ์ คอมพิวเตอร์ จำกัด	
บริษัท วิศวกรรมธรณีและธรณีวิทยา จำกัด	

SUBMITTED	
BY	
วิศวกร ชัยชนะ	
(PROJECT MANAGER) DATE : 00/MM/YY	

CIVIL ENGINEER : บริษัท พชรทอง จำกัด 00/00/00	
CIVIL ENGINEER : บริษัท วิศวกรรมธรณี และ 00/00/00	
MECHANICAL ENGINEER : บริษัท วิศวกรรมธรณี และ 00/00/00	

ARCHITECT : บริษัท วิศวกรรมธรณี และ 00/00/00	
ELECTRICAL ENGINEER : บริษัท วิศวกรรมธรณี และ 00/00/00	
ELECTRICAL ENGINEER : บริษัท วิศวกรรมธรณี และ 00/00/00	

JUL 2018	
SCALE	
SHEET No.	
150	